



FILL CERTIFICATE

PROJECT: Lot No 401 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_401

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 401 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 402 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_402

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 402 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 403 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_403

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 403 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 404 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_404

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 404 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 405 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_405

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 405 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 406 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_406

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 406 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 407 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_407

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 407 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 408 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_408

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 408 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 409 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_409

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 409 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 410 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_410

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 410 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 411 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_411

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 411 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 412 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_412

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 412 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 413 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_413

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 413 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 414 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_414

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 414 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 426 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_426

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 426 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to read 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 427 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_427

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 427 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 428 (as per Drawing No 802RD-04-04)
Florian Estate (Stage 4), Bonshaw

CLIENT: Winslow Constructors Pty Ltd
50 Barry Road
CAMPBELLFIELD VIC 3061

REPORT NO: 19232_428

DATE: 25 March 2020

SUMMARY

Civil Geotechnical Services were engaged by Winslow Constructors Pty Ltd to provide inspection and testing services on the earthworks associated with the construction of Lot 428 of Florian Estate (Stage 4), Bonshaw in a manner which would satisfy the criteria for Level 1 testing and inspection services as specified in Section 8.2 of AS 3798 - Guidelines on earthworks for commercial and residential developments (2007). The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the areas of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of the earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Winslow Constructors Pty Ltd satisfied the requirements of the Level 1 criteria specified in AS 3798 in regard to the placement of fill on a Type 1/2 Project.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential slabs and footings (2011), we are of the view that the bulk fill materials that were placed over this Lot by Winslow Constructors Pty Ltd can be considered as having been placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort). As such, the bulk fill materials would be deemed to be controlled fill that complies with Clause 1.8.13 of AS 2870. Hence, re-classification of the site to account for the fill presence is permitted under Clause 2.5.3 (c) of AS 2870.

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 16 April 2019.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock